



STANDARD LEGEND	
✕	V Valve
○	M Meter
□	D.B. Dirt Box
	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1	20mm/25mm TAPPING BAND
2	20mm/25mm BALL VALVE WESTERN WATER MAY UTILISE A FERRULE & BEND IN SOME CASES
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
4	POLYETHYLENE TO COPPER CONNECTOR
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 (CLAUSE 5.10 & 5.11) AND LOCAL COUNCIL REQUIREMENTS
6	20mm/25mm RIGHT ANGLE BALL VALVE
7	20mm/25mm WESTERN WATER SUPPLIED WATER METER. THE TYPE OF WATER METERS (20MM AND 25MM) PROCURED BY THE WATER BUSINESSES MAY VARY. WHERE WATER METERS INCORPORATE INTEGRAL DUAL CHECK VALVES, PLUMBERS ARE TO MAKE THEIR OWN ASSESSMENT WHETHER TO FIT AN ADDITIONAL CONTAINMENT BACKFLOW PREVENTION DEVICE.

ITEM NO.	DESCRIPTION
8	BACKFLOW PREVENTION DEVICE (LOW HAZARD NON-TESTABLE) REFER TO ITEM 7
9	ELBOW
10	TIMBER STAKE
11	HOSE BIB TAP
12	HOSE CONNECTION VACUUM BREAKER
13	TUBE BUSH
14	BRASS PLUG