



STANDARD LEGEND	
⊗	V Valve
○	M Meter
□	D.B. Dirt Box
—	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
4	POLYETHYLENE TO COPPER CONNECTOR
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 (CLAUSE 5.10 & 5.11) AND LOCAL COUNCIL REQUIREMENTS
6	20mm / 25mm RIGHT ANGLE BALL VALVE
7	20mm / 25mm WESTERN WATER SUPPLIED WATER METER

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
8	RESILIENT SEATED BALL VALVE
9	APPROVED LINE STRAINER
10	APPROVED HIGH HAZARD TESTABLE BACKFLOW PREVENTION DEVICE
11	ELBOW
12	TIMBER STAKE
13	HOSE BIB TAP
14	HOSE CONNECTION VACUUM BREAKER
15	TUBE BUSH
16	BRASS PLUG