



STANDARD LEGEND	
×	V Valve
○	M Meter
□	D.B Dirt Box
—	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	GATE / BALL VALVE
4	32mm - 50mm DIRT BOX
5	WESTERN WATER SUPPLIED WATER METER
6	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm
7	RESILIENT SEATED GATE / BALL VALVE
8	FILTER TO SUIT BACKFLOW PREVENTION DEVICE MANUFACTURER'S REQUIREMENTS
9	HIGH / MEDIUM TESTABLE BACKFLOW PREVENTION DEVICE TO AS2845.1
METERS 50MM AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	