



WHERE FIRE SERVICES HAVE HOSE REELS IN AREAS SUBJECT TO POTENTIAL INTERCONNECTION WITH CONTAMINANTS, THE TYPE OF BACKFLOW PREVENTION DEVICE INSTALLED AT THE WATER METER MUST BE RELEVANT TO THE HAZRD RATING OF THE PROPERTY.

STANDARD LEGEND	
✕	V Valve
○	M Meter
□	D.B Dirt Box
—	S.P. Straight Piece
⋮	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	GATE / BALL VALVE
4	DIRT BOX FOR 32mm +
5	WESTERN WATER SUPPLIED WATER METER
6	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm. NOT REQUIRED FOR 25MM SERVICES
7	SINGLE SPRING LOADED CHECK VALVE
8	APPROPRIATE APPROVED BACKFLOW PREVENTION DEVICE
METERS 50MM AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	