



STANDARD LEGEND	
×	V Valve
○	M Meter
□	D.B Dirt Box
—	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM
4	POLYETHYLENE TO COPPER CONNECTOR
5	DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 (CLAUSE 5.10 & 5.11) AND LOCAL COUNCIL REQUIREMENTS
6	20mm / 25mm RIGHT ANGLE BALL VALVE
7	20mm / 25mm WESTERN WATER SUPPLIED WATER METER

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
8	RESILIENT SEATED BALL VALVE
9	APPROVED LINE STRAINER
10	MEDIUM HAZARD TESTABLE BACKFLOW PREVENTION DEVICE
11	ELBOW
12	TIMBER STAKE
13	HOSE BIB TAP
14	HOSE CONNECTION VACUUM BREAKER
15	TUBE BUSH
16	BRASS PLUG