



PROPERTY OWNER'S RESPONSIBILITY FROM WATER MAIN EXCEPT FOR WATER METER

MAXIMUM HEIGHT OF WATER METER ASSEMBLY MAY BE EXCEEDED TO 1.5M WITH PRIOR APPROVAL FROM WESTERN WATER

WHERE FIRE SERVICES HAVE HOSE REELS IN AREAS SUBJECT TO POTENTIAL INTERCONNECTION WITH CONTAMINANTS, THE TYPE OF BACKFLOW PREVENTION DEVICE INSTALLED AT THE WATER METER MUST BE RELEVANT TO THE HAZRD RATING OF THE PROPERTY.

STANDARD LEGEND	
✕	V Valve
○	M Meter
□	D.B Dirt Box
---	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE (RESILIENT SEATED)
4	TESTABLE SINGLE DETECTOR CHECK VALVE
5	25MM BYPASS METER SUPPLIED BY WESTERN WATER. WESTERN WATER MAY REQUIRE LARGER BYPASS METERS ON A CASE BY CASE BASIS
6	25mm DUAL SPRING LOADED CHECK VALVE