



STANDARD LEGEND	
×	V Valve
○	M Meter
□	D.B Dirt Box
—	S.P. Straight Piece
⊥	T.F. Testing Ferrule
▭	L.S. Line Strainer
⌌	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
⌌	S.C.V. Single Check Valve
⌌	T.D.C.V. Testable Detector Check Valve

SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE
4	DIRT BOX. COMPULSORY FOR FIRE SERVICE. NO 'Y' STRAINER IF RPZD FITTED.
5	SPACER 5 x PIPE DIAMETER
6	WESTERN WATER SUPPLIED WATER METER
7	SPACER 3 x PIPE DIAMETER
8	TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm
9	BACKFLOW PREVENTION DEVICE AND ASSOCIATED VALVING TO BE RELEVANT TO HAZARD RATING. ILLUSTRATION REFERS TO LOW HAZARD DCV ONLY.
METERS 50MM AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	